



# Insertion flowmeter with paddle wheel for continuous flow measurement

- Economic integration in pipe systems without any additional piping
- 3-wire frequency pulse version to directly interface with PLC's (both PNP and NPN)
- · Connection to Bürkert devices in remote versions



Product variants described in the data sheet may differ from the product presentation and description.

#### Can be combined with



Type 8611 eCONTROL - Universal controller

#### Type 8025



Insertion flowmeter or batch controller with paddle wheel and flow transmitter or remote batch controller



# Type 8619

multiCELL - Multi-channel and multi-function transmitter/controller

# Type description

The paddle wheel flowmeter for continuous flow measurement is especially designed for use in neutral, slightly aggressive, solid free liquids.

The Bürkert designed fitting system ensures simple installation of the devices into all pipes from DN 20...DN 400. The flowmeter produces a frequency pulse signal, proportional to the flow rate, which can easily be transmitted and processed by a Bürkert transmitter/controller.





# **Table of contents**

1.	Gen	neral technical data	3
2.	Арр	provals	5
	2.1.	Pressure Equipment Directive	5
		Device used on a pipe	5
3.	Mat	terials	5
	3.1.	Chemical Resistance Chart – Bürkert resistApp	5
	3.2.	Material specifications	5
4.	Dim	nensions	6
	4.1.	Flowmeter	6
	4.2.	Flowmeter installed in a S020 fitting	6
5.	Per	formance specifications	7
	5.1.	Pressure temperature diagram	7
6.	Pro	duct installation	7
	6.1.	Installation notes	7
7	Pro	duct operation	8
	7 1		•
	7.1.		0
8.	Pro	duct design and assembly	8
	8.1.	Product assembly	8
9.	Net	working and combination with other Bürkert products	9
10	. Ord	lering information	9
	10.1.	Bürkert eShop – Easy ordering and quick delivery	9
	10.2.	Recommendation regarding product selection	9
	10.3.	Bürkert product filter	10
	10.4.	Ordering chart	10
	10.5.	Ordering chart accessories	10

Visit product website 🕨

บริษัท ฟลูเทค จำกัด FLU - TECH CO., TD



# 1. General technical data

## Note:

If the device is mounted in a humid environment or outside, then the maximum voltage allowed is 35 V DC instead of 36 V DC.

Product properties					
Material					
Please make sure the device materials are	compatible with the fluid you are using.				
Detailed information can be found in chapter	er "3.1. Chemical Resistance Chart – Bürkert resistApp" on page 5.				
Non wetted parts					
Housing	PE				
Union nut	PC 🦯 🦲				
Screws	Stainless steel				
Female cable plug/male fixed plug • Body, contact holder and cable gland in PA					
	Cable gland seal and flat seal in NBR				
Wetted parts					
Seal	FKM (EPDM option)				
Axis and bearings	Ceramics (Al <sub>2</sub> O <sub>3</sub> )				
Sensor armature, paddle wheel	PVDF				
Dimensions	Detailed information can be found in chapter "4. Dimensions" on page 6.				
Measuring principle	Paddle wheel				
Compatibility	Any pipe from DN 20DN 400 which is fitted with Bürkert S020 Insertion fitting. For the selection of the nominal diameter of the Insertion fittings, see <b>data sheet Type</b>				
	S020 ▶.				
Pipe diameter	DN 20DN 400				
Measuring range	<ul> <li>Flow rate: 0.575000 l/min (0.1319813 gpm)</li> </ul>				
	Flow velocity: 0.310 m/s				
Performance data	0.00 / 0				
Measurement deviation	<ul> <li>Teach-In: ±1% of the measured value<sup>1,)</sup> at Teach-In flow rate value</li> </ul>				
	<ul> <li>Standard K-factor: ±2.5% of the measured value<sup>1.)</sup></li> </ul>				
Linearity	±0.5% of full scale <sup>1)</sup>				
Repeatability	±0.4% of the measured value <sup>1.)</sup>				
Electrical data					
Operating voltage	Pulse version: 1236 V DC, filtered and regulated				
	Connection to main supply: permanent (through external SELV (Safety Extra Low				
	Voltage) and LPS (Limited Power Source) power supply				
	Pulse "Low Power" version: via Bürkert transmitter				
Power source (not supplied)	Limited power source according to UL/EN 60950-1 standards or limited energy circuit according to UL/EN 61010-1 §9.4				
DC reverse polarity protection	Yes				
Overvoltage protection	Yes				
Current consumption	With sensor				
	<ul> <li>Pulse version: ≤50 mA</li> </ul>				
	<ul> <li>Pulse "Low Power" version: ≤0.8 mA</li> </ul>				
Outputs	Pulse version:				
	<ul> <li>Transistor NPN/PNP, open collector</li> </ul>				
	– max. 100 mA				
	– 0300 Hz				
	<ul> <li>duty cycle (pulse duration/period): ½</li> </ul>				
	Pulse "I ow Power" version:				
	- Transistor NDN open collector				
	– max. 10 mA				
	– 0300 Hz				

- duty cycle (pulse duration/period): 1/2

Visit product website 🕨

FluTech

บริษัท ฟลูเทค จำกัด FLU - TECH CO., TD 845/3-4 หมู่ 3 ถ.เทพารักษ์ ต.เทพารักษ์ อ.เมือง จ.สมุทรปราการ 102070 845/3-4 Thepaharak RD., T. Thepharak, A. Muang, Samutprakan 10270 THAILAND

Tel. 0 2384 6060, Fax 0 2384 5701, Email : sales@flutech.co.th, www.flutech.co.th



Voltage supply cable	Max. 50 m length, shielded			
	Cross section of wires: 0.251.5 mm <sup>2</sup>			
Medium data				
Fluid temperature	With fitting Type S020 in:			
	• PVC: 0+50 °C (+32+122 °F)			
	• PP: 0+80 °C (+32+176 °F)			
	<ul> <li>PVDF, stainless steel or brass: -15+80 °C (+5+176 °F)</li> </ul>			
	See data sheet Type S020 > for more information.			
Fluid pressure	Max. PN 10 Detailed information can be found in chapter "5.1. Pressure temperature diagram" on page 7 or see data sheet Type S020 ▶ for more information.			
Viscosity	Max. 300 cSt			
Rate of solid particles	Max. 1 %			
Maximum particle size	0.5 mm			
Process/Port connection & communication	ation			
Process connection	G 2 <sup>+</sup> for use with Type S020 Insertion fitting See data sheet Type S020 ▶ for more information.			
Electrical connection	Female cable plug according to EN 175301-803			
Approvals and Certificates				
Standards				
Degree of protection according to IEC/ EN 60529	IP65 with cable plug mounted and tightened			
Directives				
CE directives	The applied standards, which verify conformity with the EU Directives, can be found on the EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable)			
Pressure equipment directives	Complying with Article 4, Paragraph 1 of 2014/68/EU directive			
	Detailed information on the pressure equipment directive can be found in chapter "2.1. Pressure Equipment Directive" on page 5.			
Environment and installation				
Ambient temperature	Operation and storage: -15+60 °C (+5+140 °F)			
Relative air humidity	≤80%, without condensation			
Height above sea level	Max. 2000 m			
Operating condition	Continuous			
Equipment mobility	Fixed			
Application range	Indoor and outdoor (protect the device against electromagnetic interference, ultraviolet rays and, when installed outdoors, against the effects of climatic conditions)			
Installation category	Category I according to UL/EN 61010-1			
Pollution degree	Degree 2 according to UL/EN 61010-1			

1.) Under reference conditions i.e. measuring fluid = water, ambient and water temperature = 20 °C (68 °F), while maintaining the minimum inlet and outlet distances and the appropriate internal diameters of the pipes.

Visit product website >



บริษัท ฟลูเทค จำกัด FLU - TECH CO., TD

845/3-4 หมู่ 3 ถ.เทพารักษ์ ต.เทพารักษ์ อ.เมือง จ.สมุทรปราการ 102070 845/3-4 Thepaharak RD., T. Thepharak, A. Muang, Samutprakan 10270 THAILAND

845/3-4 Thepaharak RD., T. Thepharak, A. Muang, Samutprakan 10270 THAILAND Tel. 0 2384 6060, Fax 0 2384 5701, Email : sales@flutech.co.th, www.flutech.co.th



# 2. Approvals

#### 2.1. Pressure Equipment Directive

The device conforms to Article 4, Paragraph 1 of the Pressure Equipment Directive 2014/68/EU under the following conditions:

#### Device used on a pipe

#### Note:

- The data in the table is independent of the chemical compatibility of the material and the fluid.
- PS = maximum admissible pressure, DN = nominal diameter of the pipe

Type of fluid	Conditions
Fluid group 1, Article 4, Paragraph 1.c.i	DN ≤25
Fluid group 2, Article 4, Paragraph 1.c.i	DN ≤32 or PS*DN ≤1000
Fluid group 1, Article 4, Paragraph 1.c.ii	DN ≤25 or PS*DN ≤2000
Fluid group 2, Article 4, Paragraph 1.c.ii	DN ≤200 or PS ≤10 or PS*DN ≤5000

# 3. Materials

#### 3.1. Chemical Resistance Chart – Bürkert resistApp



#### Bürkert resistApp – Chemical Resistance Chart

You want to ensure the reliability and durability of the materials in your individual application case? Verify your combination of media and materials on our website or in our resistApp.

Start Chemical Resistance Check

#### 3.2. Material specifications



No.	Element	Material						
1	Screw	Stainless steel						
2	Female cable plug/male fixed plug	• Body, contact holder and cable gland in PA						
		• Cable gland seal and flat seal in NBR						
3	Housing	PE						
4	Union nut	PC						
5	Seal	FKM (EPDM option)						
6	Sensor armature	PVDF						
7	Axis and bearings	Ceramics (Al <sub>2</sub> O <sub>3</sub> )						
8	Paddle wheel	PVDF						

#### Visit product website >



บริษัท ฟลูเทค จำกัด FLU - TECH CO., TD



# 4. Dimensions

#### 4.1. Flowmeter

Note: Specifications in mm



## 4.2. Flowmeter installed in a S020 fitting

#### Note: Specifications in mm

DN	H						
	T-Fitting	Saddle	Plastic spigot	Metal spigot			
20	160.5	-	-	-			
25	160.5	-	-	-			
32	164.0	-	-	-			
40	168.0	-	-	-			
50	174.0	198.5	-	169.5			
65	174.0	197.5	179.5	174.0			
80	-	201.5	184.5	180.0			
100	-	206.5	191.0	190.5			
110	-	202.5	-	-			
125		209.5	-	201.5			
150	- 9	219.5	237.0	212.5			
180	-	243.5	-	-			
200	-	255.5	258.0	233.0			
250	-	-	276.0	293.0			
300	-	-	287.5	312.5			
350	-	-	301.0	324.5			
400	-	-	315.5	-			

Visit product website >



บริษัท ฟลูเทค จำกัด FLU - TECH CO., TD



# 5. Performance specifications

#### 5.1. Pressure temperature diagram



# 6. Product installation

#### 6.1. Installation notes

#### Note:

The flowmeter is not designed for gas and steam flow measurement.

Minimum straight upstream and downstream distances must be observed. According to the pipe's design, necessary distances can be bigger or use a flow conditioner to obtain the best accuracy.

Fore more information, please refer to EN ISO 5167-1.

EN ISO 5167-1 specifies the straight inlet and outlet distances that must be complied with when installing fittings in pipe lines in order to achieve calm flow conditions. The most important layouts that could lead to turbulence in the flow are shown below, together with the associated specified minimum inlet and outlet distances.

Make sure that the measuring conditions at the point of measurement are calm and problem-free.



If the valve cannot be mounted after the measuring device, the minimal distances have to be respected.
 If an expansion cannot be avoided, the minimal distances have to be respected.
 Please note minimum flow velocity

The flowmeter can be installed into either horizontal or vertical pipes. Important criteria for this are; ensure that the measurement pipe is fully filled and that the measurement pipe is free of bubbles.

#### Visit product website

7 | 11

# burkert



Pressure and temperature ratings must be respected according to the selected fitting material. The suitable pipe size is selected using the diagram for selecting the nominal diameter of the fitting, see **data sheet Type S020** • for more information.

# 7. Product operation

#### 7.1. Measuring principle

When liquid flows through the pipe, the paddle wheel with 4 inserted magnets is set in rotation, producing a measuring signal in the sensor (Hall sensor). The frequency modulated induced voltage is proportional to the flow velocity of the fluid. A K-factor (available in the instruction manual of the S020 fitting), specific to each pipe (size and material) enables the conversion of this frequency into a flow rate.

Two electronic module versions with frequency output are available:

- with one pulse output (either NPN or PNP transistor output depending on wiring). An external power supply of 12...36 V DC is required. It is designed for connection to any system with open collector NPN or PNP frequency input.
- with one pulse "Low Power" output (NPN transistor output). An external power supply of 12...36 V DC is required. Can only be connected to separate versions of flow transmitters Type 8025.

In a 3-wire system, the signal can be displayed or processed directly. The electrical connection is provided via a cable plug according to EN 175301-803.

# 8. Product design and assembly

#### 8.1. Product assembly

# Note:

- The 8020 flowmeter can easily be installed into any Bürkert Insertion fitting system (S020) by just fixing the main nut.
- The S020 Insertion fitting ensures simple installation into pipes from DN 20...DN 400.

See data sheet Type S020 ▶ for more information.

The flowmeter 8020 consists of a transducer and a paddle-wheel with ceramic bearings. The ceramic rotating axis is set on the end of an insertion sensor armature. The transducer is mounted inside the armature.

Visit product website



บริษัท ฟลูเทค จำกัด FLU - TECH CO., TD

Type 8020



# 9. Networking and combination with other Bürkert products

Example:



# 10. Ordering information

10.1. Bürkert eShop – Easy ordering and quick delivery



# 10.2. Recommendation regarding product selection

#### Note:

A complete flow measurement equipment consists of a flowmeter Type 8020 and a Bürkert Insertion fitting Type S020.

See data sheet Type S020 > for more information.

Two different components must be ordered in order to select a complete device. The following information is required:

- Article no. of the desired flowmeter Type 8020 (see chapter "10.4. Ordering chart" on page 10)
- Article no. of the selected S020 Insertion fitting (See data sheet Type S020 ▶)

Visit product website

FluTech

บริษัท ฟลูเทค จำกัด FLU - TECH CO., TD



#### 10.3. Bürkert product filter

8	Francis Con	nection	5 Voltage / Frequency	Process	Pressure / Sealing
	Advanced Th	- (	Colupse al fibers		
Norminal p	pressure min		Nominal prossure max		Nominal pressure may
Nonital p	pressure min	Dar	Nominal prossure max		Nominal pressure max (gas)
Honinal y	protouro min	bar 0.5	Nominal pressure max	bar 5	Nominal pressure max (gas) 2.5

#### Bürkert product filter - Get quickly to the right product

You want to select products comfortably based on your technical requirements? Use the Bürkert product filter and find suitable articles for your application quickly and easily.

Try out our product filter

#### 10.4. Ordering chart

Description	Operating voltage	Output	Sensor version	Electrical connection	Article no.
Pulse version flowmeter (pluggable	1236 V DC	Frequency with pulse, PNP or NPN	Short	Female cable plug EN 175301-803	419587 🐖
to Types 8025 Universal transmitter, batch controller; 8619; PLC)			Long		419589 🛒
Pulse "Low Power" version flowmeter	From associated transmitter	Frequency with pulse, NPN	Short		419591 🐖
(pluggable to Type 8025 transmitter)			Long		419593 ቛ

#### 10.5. Ordering chart accessories

Description	Article no.
Set with 1 green FKM and 1 black EPDM gasket	552111 🛒
Ring	619205 🛒
Union nut	619204 🛒
Female cable plug EN 175301-803 with cable gland - see Type 2518	572264 🛒
Cable plug EN 175301-803 with NPT ½" reduction without cable gland - see Type 2509 ▶	162673 🛒



บริษัท ฟลูเทค จำกัด FLU - TECH CO., TD