DATA SHEET





Radar level meter for aggressive media

- For level measurement up to 20 m
- 4...20 mA/Hart, 2 wires
- · Adjustable with display/configuration module or PC
- ATEX approvals
- Insensitive to variations of temperature, pressure, medium data of the product and gas layers





Product variants described in the data sheet may differ from the product presentation and description.

Can be combined with



Type 8635 Digital electropneumat-

Digital electropneumatic Positioner SideControl



Type 8692

Digital electropneumatic Positioner for the integrated mounting on process control valves



Type 8644
Remote Process Actuation Control System

AirLINE

Type description

Type 8136 is a non-contact radar level meter for continuous level measurement.

The unit is available in two variants:

- with encapsulated horn antenna.
 Particularly suitable for the level measurement of aggressive liquids in small vessels.
- with plastic horn antenna.
 Particularly suitable for flow measurement in open flumes or gauge measurement in waters.





Table of contents

| 1. | 1. General technical data | 3 |
|----|---|----------|
| 2 | 2. Product versions | 5 |
| ۷. | | <u> </u> |
| | 2.1. Encapsulated horn antenna | |
| | 2.2. Plastic horn antenna | 5 |
| 3. | 3. Approvals | 6 |
| | 3.1. ATEX-Certification | |
| | O.T. THEX COMMODITION | 1 |
| 4. | 4. Materials | 6 |
| | 4.1. Chemical Resistance Chart – Bürkert resistApp | 6 |
| | ·· | |
| 5. | 5. Dimensions | 7 |
| | 5.1. Version with encapsulated horn antenna | 7 |
| | 5.2. Version with plastic horn antenna | |
| | | |
| 6. | | 8 |
| | 6.1. Measurement deviation diagram | 8 |
| | Version with encapsulated horn antenna | |
| | Version with plastic horn antenna | 8 |
| 7. | 7. Product installation | 9 |
| | 7.1. Mounting options | |
| | Version with plastic horn antenna 80 mm with mounting bracket | |
| | Version with plastic horn antenna 80 mm with flange | |
| | / / / / / / / / / / / / / / / / / / / | |
| 8. | 8. Product operation | 10 |
| | 8.1. Measuring principle | 10 |
| | 8.3. Product operation notes | 10 |
| | Operating techniques | 10 |
| | Set up with display/configuration module | 10 |
| | Set up with PACTware™/DTM and HART communication | 11 |
| ^ | O. Duadust assessing | 44 |
| 9. | 9. Product accessories | 11 |
| | | |
| 10 | 10. Ordering information | 12 |
| | 10.1. Bürkert eShop – Easy ordering and quick delivery | 12 |
| | 10.2. Bürkert product filter | 12 |
| | 10.3. Ordering chart | |
| | 10.4. Ordering chart accessories | 13 |

Visit product website >





1. General technical data

Product properties

Material

Please make sure the device materials are compatible with the fluid you are using.

Detailed information can be found in chapter "4.1. Chemical Resistance Chart - Bürkert resistApp" on page 6.

Non wetted parts

Depending on the device version.

Detailed information can be found in chapter "2. Product versions" on page 5.

Housing PBT, stainless steel 316L (1.4404)

Cover PC transparent

Seal between housing and cover EPDM Cable gland PA Blind plug PA

Ground terminal Stainless steel 316Ti/316L (1.4571/1.4435)

Wetted parts

Depending on the device version.

Detailed information can be found in chapter "2. Product versions" on page 5.

| Dimensions | Detailed information can be found in chapter "5. Dimensions" on page 7. |
|-------------------------------------|---|
| Weights | 0.73.4 kg (depending on process connection and antenna) |
| Measuring variable | Distance between the end of the level meter antenna and the product surface. Detailed information can be found in chapters "6.1. Measurement deviation diagram" on page 8 and "8.1. Measuring principle" on page 10. |
| Measuring range | Max. 20 m (depending on the device version). Detailed information can be found in chapter "2. Product versions" on page 5. |
| Beam angle ^{1.)} | Depending on the device version. Detailed information can be found in chapter "2. Product versions" on page 5. |
| Damping (63 % of the input value) | 0999 s, adjustable |
| Step response time ^{2.)} | ≤3 s |
| Product accessories | |
| Display | LCD in full dot matrix (optional, must be ordered separately). Detailed information can be found in chapter "10.4. Ordering chart accessories" on page 13. |
| Performance data | |
| Measurement deviation | ±2 mm (measuring distance > 0.5 m) Detailed information can be found in chapter "4.1. Measurement deviation diagram" on page 3. |
| Measuring range resolution | 1 mm |
| Measuring frequency | K-Band (26 GHz technology) |
| Measuring cycle time | Approx. 450 ms |
| Temper <mark>a</mark> ture drift | Digital output: ±3 mm/10 K, max. 10 mm |
| | Current output: <0.03 %/10K relating to the 16 mA span or ≤0.3 % |
| Non-repeatability ^{3.)} | ≤1 mm |
| Vibration resistance | Depending on the device version. Detailed information can be found in chapter "2. Product versions" on page 5. |
| Shock resistance | 100 g, 6 ms according to EN 60068-2-27 (mechanical shock) |
| Electrical data | |
| Operating voltage (U _n) | Without display/configuration module: |
| | - 9.635 V DC |
| | - 9.630 V DC (Ex ia instrument) |
| | With display/configuration module: |
| | - 1635 V DC |
| | - 1630 V DC (Ex ia instrument) |
| Power Source (not supplied) | Limited power source according to UL/EN 60950-1 standards or limited energy circuit according to UL/EN 61010-1 §9.4 |
| Starting current | ≤3.6 mA; ≤10 mA for 5 ms after switching on |
| DC reverse polarity protection | Yes |
| Output signal | 420 mA/HART |
| Signal resolution | 0.3 μΑ |

Visit product website ▶ 3 | 14



| Range of the output signal | 3.820.5 mA/HART (default setting) | | | |
|--|---|--|--|--|
| Load resistor | (U _n - U _{min})/0.022 A | | | |
| Fault signal | Current output: mA value unchanged, 20.5 mA, 22 mA or <3.6 mA (adjustable) | | | |
| Max. output current | 22 mA | | | |
| Residual ripple (for DC) | • For $9.6 \text{ V} < U_n < 18 \text{ V}: \le 0.7 \text{ V}_{\text{eff}} (16400 \text{ Hz})$ | | | |
| | • For 18 V $<$ U _n $<$ 35 V: \le 1.0 V _{eff} (16400 Hz) | | | |
| Voltage supply cable | Cable diameter: 59 mm | | | |
| | Wire cross-section (spring-loaded terminals): | | | |
| | massive wire, stranded wire: 0.22.5 mm² (AWG 2414) | | | |
| | - stranded wire with end sleeve: 0.21.5 mm ² (AWG 2416) | | | |
| Medium data | | | | |
| Process temperature | -40 °C+80 °C (-40 °F+176 °F) | | | |
| Process pressure | Depending on the device version. Detailed information can be found in chapter "2. Product versions" on page 5. | | | |
| Dielectric constant (min.) | εr>1.6 | | | |
| Process/Port connection & commu | unication | | | |
| Process connection | Depending on the device version. Detailed information can be found in chapter "2. Product versions" on page 5. | | | |
| Electrical connection | Cable glands M20 x 1.5 | | | |
| Approvals and Certificates | | | | |
| Standards | | | | |
| Degree of protection according to IEC/EN 60529 | IP66/IP67 with M20 x 1.5 gland mounted and tightened | | | |
| Overvoltage category according to IEC 61010-1 | Category III | | | |
| Protection class according to IEC 61010-1 | Class III | | | |
| Directives | | | | |
| | | | | |
| CE directives | | | | |
| | The applied standards, which verify conformity with the EU Directives, can be found on the EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 – Electromagnetic compatibility of equipment | | | |
| | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) | | | |
| | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 – Electromagnetic compatibility of equipment | | | |
| | NE21 – Electromagnetic compatibility of equipment NE43 – Signal level for fault information from measuring transducers NE53 - Compatibility of field devices and display/adjustment components | | | |
| NAMUR recommendations | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 – Electromagnetic compatibility of equipment NE43 – Signal level for fault information from measuring transducers | | | |
| NAMUR recommendations Approvals | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 - Electromagnetic compatibility of equipment NE43 - Signal level for fault information from measuring transducers NE53 - Compatibility of field devices and display/adjustment components NE107 - Self-monitoring and diagnosis of field devices | | | |
| NAMUR recommendations Approvals | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 - Electromagnetic compatibility of equipment NE43 - Signal level for fault information from measuring transducers NE53 - Compatibility of field devices and display/adjustment components NE107 - Self-monitoring and diagnosis of field devices EN 60079-0, EN 60079-11, EN 60079-26 | | | |
| NAMUR recommendations Approvals ATEX | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 - Electromagnetic compatibility of equipment NE43 - Signal level for fault information from measuring transducers NE53 - Compatibility of field devices and display/adjustment components NE107 - Self-monitoring and diagnosis of field devices | | | |
| NAMUR recommendations Approvals ATEX Environment and installation | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 - Electromagnetic compatibility of equipment NE43 - Signal level for fault information from measuring transducers NE53 - Compatibility of field devices and display/adjustment components NE107 - Self-monitoring and diagnosis of field devices EN 60079-0, EN 60079-11, EN 60079-26 Detailed information can be found in chapter "3.1. Certification ATEX" on page 6. | | | |
| NAMUR recommendations Approvals ATEX Environment and installation Ambient temperature | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 - Electromagnetic compatibility of equipment NE43 - Signal level for fault information from measuring transducers NE53 - Compatibility of field devices and display/adjustment components NE107 - Self-monitoring and diagnosis of field devices EN 60079-0, EN 60079-11, EN 60079-26 Detailed information can be found in chapter "3.1. Certification ATEX" on page 6. Operation and storage: -40 °C+80 °C (-40 °F+176 °F) | | | |
| Approvals ATEX Environment and installation Ambient temperature Relative air humidity | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 – Electromagnetic compatibility of equipment NE43 – Signal level for fault information from measuring transducers NE53 - Compatibility of field devices and display/adjustment components NE107 - Self-monitoring and diagnosis of field devices EN 60079-0, EN 60079-11, EN 60079-26 Detailed information can be found in chapter "3.1. Certification ATEX" on page 6. Operation and storage: -40 °C+80 °C (-40 °F+176 °F) 2085 %, without condensation | | | |
| CE directives NAMUR recommendations Approvals ATEX Environment and installation Ambient temperature Relative air humidity Height above sea level | EU Type Examination Certificate and/or the EU Declaration of conformity (if applicable) NE21 - Electromagnetic compatibility of equipment NE43 - Signal level for fault information from measuring transducers NE53 - Compatibility of field devices and display/adjustment components NE107 - Self-monitoring and diagnosis of field devices EN 60079-0, EN 60079-11, EN 60079-26 Detailed information can be found in chapter "3.1. Certification ATEX" on page 6. Operation and storage: -40 °C+80 °C (-40 °F+176 °F) 2085 %, without condensation | | | |

- 1.) Outside the specified beam angle, the energy level of the radar signal is $50\,\%$ (-3 dB) less
- 2.) Time span after a sudden measuring distance change by max. 0.5 m in liquid applications, max 2 m with bulk solids applications, until the output signal has taken for the first time 90 % of the final value (IEC 61298-2)
- 3.) Already included in the measuring deviation

Visit product website ▶ 4 | 14



2. Product versions


2.1. Encapsulated horn antenna



| Product details | | | |
|---------------------------|---|--|--|
| Material | Wetted parts: | | |
| | Process connection made of PVDF | | |
| | Antenna made of PVDF (completely encapsulated) | | |
| | Seal made of FKM | | |
| Beam angle ^{1.)} | 22° | | |
| Measuring range | 0.0510 m | | |
| Vibration resistance | 4 g with 5200 Hz according to EN 60068-2-6 (vibration at resonance) | | |
| Process connection | Thread G 1½" or NPT 1½" | | |
| Process pressure | Vessel pressure: -13 bar (-100300 kPa/-14.543.5 psi) | | |

^{1.)} Outside the specified beam angle, the energy level of the radar signal is 50 % (-3 dB) less

2.2. Plastic horn antenna



| Product details | | | | |
|---------------------------|--|--|--|--|
| Material | Ion wetted parts: Mounting strap made of stainless steel 316L (1.4435) Fixing screws made of stainless steel 316L (1.4435) Vetted parts: Antenna made of PBT-GF30 Focus lens made of PP | | | |
| Beam angle ^{1.)} | 10° | | | |
| Measuring range | 020 m | | | |
| Vibration resistance | With mounting strap: 1 g with 5200 Hz according to EN 60068-2-6 (vibration at resonance) With adapter flange (in option): 2 g with 5200 Hz according to EN 60068-2-6 (vibration at resonance) | | | |
| Process connection | Mounting bracket 170 mm | | | |
| Process pressure | Vessel pressure: -12 bar (-100200 kPa/-14.529.0 psi) Version with adapter flange from DN 100: -11 bar (-100100 kPa/-14.514.5 psi) | | | |
| Accessories | | | | |
| Material | Non wetted parts: • Adapter flange fixing screw made of stainless steel 304 Wetted parts: • Adapter flange made of PP-GF30 black | | | |
| | Sealing of the adaptor flange made of FKM (COG VI500) | | | |

^{1.)} Outside the specified beam angle, the energy level of the radar signal is $50\,\%$ (-3 dB) less

Visit product website ▶ 5 | 14



3. Approvals

3.1. Certification ATEX

Note:

Devices with Ex certification have different technical data, see Supplement ATEX Type 8136 b under user manual.

Certificate

Description



EU-Type Examination Certificate Number:

PTB 08 ATEX 2002X

ATEX

- II 1/2G Ex ia IIC T6 Ga/Gb
- II 2G Ex ia IIC T6 Gb

Measures to comply with ATEX requirements: refer to the **Supplement ATEX Type 8136** ▶ under user manual. The Ex. certification is only valid if the Bürkert device is used as described in the supplement ATEX. If unauthorized changes are made to the device, the Ex. certification becomes invalid.

4. Materials

4.1. Chemical Resistance Chart – Bürkert resistApp



Bürkert resistApp - Chemical Resistance Chart

You want to ensure the reliability and durability of the materials in your individual application case? Verify your combination of media and materials on our website or in our resistApp.

Start Chemical Resistance Check


Visit product website ▶ 6 | 14



5. Dimensions

5.1. Version with encapsulated horn antenna


Note:



5.2. Version with plastic horn antenna

Note:

Dimensions in mm




Visit product website ▶ 7 | 14

burkert


6. Performance specifications

6.1. Measurement deviation diagram

Version with encapsulated horn antenna



Version with plastic horn antenna



Visit product website ▶ 8 | 14




7. **Product installation**

7.1. Mounting options


Version with plastic horn antenna 80 mm with mounting bracket

The mounting bracket allows simple mounting of the instrument on a wall, ceiling or boom. Especially in the case of open flumes, this is a simple and effective way to align the sensor to the surface of the liquids.



Version with plastic horn antenna 80 mm with flange

An adapter flange is available for mounting the device on a socket.



9 | 14 Visit product website




8. Product operation

8.1. Measuring principle

The radar measuring device consists of an electronic housing, a process connection element with antenna and a sensor. The antenna emits short radar pulses with a duration of approximate 1 ns to the medium. These pulses are reflected by the medium surface and received by the antenna as echoes. Radar waves travel at the speed of light. The running time of the radar pulses from emission to reception is proportional to the distance and hence to the level. The determined level is converted into an output signal and transmitted as a measured value.

The measuring range of the radar level measuring device begins physically at the end of the antenna. However, the min./max. adjustment begins at the reference plane. The position of the reference plane depends on the sensor version.

- Version with encapsulated horn antenna: the reference plane is the sealing surface on the hexagon.
- Version with plastic horn antenna: the reference plane is the lower side of the flange.



8.2.

8.3. Product operation notes

Operating techniques

The measuring device provides different operating techniques:

- · the display/configuration module
- the suitable Bürkert DTM in conjunction with adjustment software according to the FDT/DTM standard, e.g. PACTware™ and PC
- a HART handheld

The entered parameters are generally saved in the measuring device Type 8136. Optionally, parameters may also be uploaded and downloaded with the display/configuration module or saved in a file by using PACTware™/8136-DTM.

Set up with display/configuration module

Display/configuration module


Description

The display/configuration module can be inserted into the measuring device and removed again at any time. It is not necessary to interrupt the power supply. The measuring device is adjusted via the four keys of the display/configuration module.

Visit product website ▶ 10 | 14




Set up with PACTware™/DTM and HART communication



9. Product accessories


Note:

The accessories for the plastic horn antenna 80 mm must be ordered separately.



Visit product website ▶ 11 | 14





10. Ordering information

10.1. Bürkert eShop - Easy ordering and quick delivery



Bürkert eShop – Easy ordering and fast delivery

You want to find your desired Bürkert product or spare part quickly and order directly? Our online shop is available for you 24/7. Sign up and enjoy all the benefits.

Order online now

10.2. Bürkert product filter



Bürkert product filter - Get quickly to the right product

You want to select products comfortably based on your technical requirements? Use the Bürkert product filter and find suitable articles for your application quickly and easily.

Try out our product filter

Visit product website ▶ 12 | 14



10.3. Ordering chart

All following versions are supplied without display/configuration module.

| Operating voltage | Output | Antenna version | Process connection | Electrical connection | Article no. |
|-------------------------|---------------------------|----------------------------------|--------------------|-----------------------|-------------|
| Standard version | | | | | |
| 9.635 V DC | 420 mA/HART (2 wires) | Encapsulated horn antenna, 40 mm | G 1½" | Cable gland M20 x 1.5 | 560146 ≒ |
| | | | NPT 1½" | | 560148 ≒ |
| | | Plastic horn antenna, 80 mm | Mounting bracket | | 560150 📜 |
| Ex version – ATEX appro | x version – ATEX approval | | | | |
| | 420 mA/HART (2 wires) | Encapsulated horn antenna, 40 mm | G 1½" | Cable gland M20x1.5 | 560147 ≒ |
| | | | NPT 1½" | | 560149 ≒ |
| | | Plastic horn antenna, 80 mm | Mounting bracket | | 560151 ≒ |

Further versions on request



Process connection

- Clamp 2", 3"
- Slotted nut DN 50, DN 80 PN 3, DIN 11851 / 316L,
- Compression flange suitable for flanges DN 80 PN 16, ANSI 3", JIS DN 80 10K / PP-GF30
- Adapter flange:
 - DN 150 PN 16 FKM / PP-GF30
 - ANSI 4" 150PSI FKM / PP-GF30
 - ANSI 6" 150PSI FKM / PP-GF30
 - JIS DN 100 10K FKM / PP-GF30
 - JIS DN 150 10K FKM / PP-GF30

10.4. Ordering chart accessories

| Description | Article no. |
|---|-------------|
| Set with 2 reductions M20 x 1.5/NPT½" + 2 neoprene flat seals for cable gland + 2 screw-plugs M20 x 1.5 | 551782 ≒ |
| Hart-USB Modem | 560177 ≒ |
| Set with a display/configuration module, a transparent cover and a seal ring | 559279 ≒ |
| Set with a transparent cover and a seal ring | 561006 ≒ |
| Mounting bracket 300 mm | 559839 ≒ |
| Adapter flange DN 100 PN 16 FKM / PP-GF30 | 560437 ≒ |
| Adapter flange ASME (ANSI B16.5) 4" 150PSI FKM / PP-GF30 | 560436 ≒ |

Visit product website ▶ 13 | 14



